

RISK ASSESSMENT SHEET

Management of health and safety at work regulations 1999.

All sites are hard hat areas.

Hard hats, safety boots and hi viz jackets must be worn at all times.

<u>TASK DETAIL</u>	<u>HAZARD DETAIL</u>	<u>RISK RANKING</u>	<u>CONTROL OF PROCEDURE</u>	<u>RESIDUAL RISK</u>
WORKING AT HEIGHT	FALLING RESULTING IN INJURY TO PERSONNEL	HIGH	WHERE ANY WORK IS REQUIRED ON SITE ABOVE 2 METRES FROM GROUND LEVEL AND WHERE STAIRCASES OR WALK WAYS ARE NOT AVAILABLE PERSONNEL WILL USE SECURED LADDERS, SUITABLE SCAFFOLDING OR A SAFETY HARNESS.	LOW
THE WEARING OF PERSONAL PROTECTIVE EQUIPMENT	INJURY TO PERSONNEL IF NOT WORN	HIGH	ALL PERSONNEL TO WEAR HARD HAT, SAFETY BOOTS AND HI VIZ JACKETS. ADDITIONAL EQUIPMENT TO BE WORN IF SITE CONDITIONS DETERMINE. IE EYE GOGGLES, EAR DEFENDERS, ETC.	LOW
WORKING WITH ELECTRICAL EQUIPMENT	ELECTRIC SHOCK RESULTING IN FATAL INJURY TO SELF AND OTHER PERSONNEL	HIGH	DEALING WITH ELECTRICAL EQUIPMENT IS A SPECIFIC TASK AND ONLY SKILLED PERSONNEL WILL DO THIS. ALL RELEVANT PERSONNEL WILL BE FULLY QUALIFIED AND HAVE UP TO DATE KNOWLEDGE OF THE CURRENT L.E.E REGULATIONS.	LOW
SITE WORKING	INCIDENT/INJURY CAUSED BY OTHERS WORKING IN THE SAME AREA AS A.HILL REFURBISHMENTS	MEDIUM	CLIENT TO ENSURE THAT ALL PERSONNEL ARE AWARE OF ACTIVITIES BEING CARRIED OUT BY A.HILL REFURBISHMENTS.	LOW
USE OF HAND ELECTRICAL EQUIPMENT	INJURY TO PERSONNEL	HIGH	ENSURE THAT ALL PERSONNEL REQUIRED TO USE THE EQUIPMENT ARE FULLY CONVERSANT WITH A PARTICULAR ITEM. USE CHOPPED VOLTAGE TO REDUCE ELECTRIC SHOCK	LOW
<u>TASK DETAIL</u>	<u>HAZARD DETAIL</u>	<u>RISK RANKING</u>	<u>CONTROL OF PROCEDURE</u>	<u>RESIDUAL RISK</u>

USE OF DIESEL POWERED HANDING EQUIPMENT IN CONFINED AREAS	DISCOMFORT/ INJURY DUE TO FUME INHALATION	LOW/ MEDIUM	AREAS WHERE DIESEL EQUIPMENT IS TO BE USED ARE TO BE VENTILATED AS MUCH AS POSSIBLE AND ALL NON ESSENTIAL PERSONNEL KEPT CLEAR OF WORKING AREAS.	LOW
USE OF OXY/ PROPANE AND WELDING EQUIPMENT	INJURY TO PERSONNEL AND SURROUNDING AREAS	HIGH	WHERE THE USE OF BURNING/ WELDING EQUIPMENT IS EXPECTED WITHIN THE SCOPE OF A CONTRACT, SUITABLE VENTILATION IS TO BE PROVIDED AND ALL POTENTIALLY COMBUSTIBLE MATERIALS ARE REMOVED FROM THE AREA AND THAT SUITABLE ESTINGUISHERS ARE AVAILABLE	LOW
DEMOLITION	POSSIBLE INJURY TO PERSONNEL AND SURROUNDING PROPERTY	HIGH	IN ALL ASPECTS OF DEMOLITION THE UPMOST CARE WILL BE TAKEN BY PERSONNEL USING THE RIGHT EQUIPMENT FOR EACH SPECIFIC TASK. ALL NON ESSENTIAL PERSONNEL WILL BE KEPT CLEAR OF WORKING AREAS. HEALTH AND SAFETY REGULATIONS WILL BE OBSERVED AT ALL TIMES	LOW
WORKING WITH GAS INSTALLATIONS	GAS EXPLOSION/ FIRE RESULTING IN FATAL INJURY TO PERSONNEL AND DAMAGE TO PROPERTY	HIGH	ALL PERSONNEL WORKING ON GAS INSTALLATIONS WILL BE FULLY QUALIFIED GAS FITTERS AND WILL BE CORGI REGISTERED.	LOW
PERSONNEL ARRIVE ON SITE	UNAWARE OF SITE REGULATIONS AND CONDITIONS	MEDIUM	REPORT TO CUSTOMER AND BE AWARE OF SITE REGULATIONS INCLUDING METHOD STATEMENTS, SITE INDUCTIONS AND ANY SITE RESTRICTIONS	LOW
WORKING WITH HAZARDOUS MATERIALS	INJURY TO PERSONNEL/ DAMAGE TO PROPERTY	HIGH	THESE MATERIALS WILL BE CLEARLY MARKED. ALL PERSONAL PROTECTIVE EQUIPMENT WILL BE WORN. ALL NON ESSENTIAL PERSONNEL WILL BE KEPT CLEAR OF WORKING AREA. SUITABLE VENTILATION IS TO BE PROVIDED. WHEN NOT BEING ALL MATERIALS WILL BE STORED IN A SAFE PLACE.	LOW